

No part of a report of a marine casualty investigation shall be admissible as evidence in any civil or administrative proceeding, other than an administrative proceeding initiated by the United States Maritime Service.



VSC Fire & Security

3117 Miller Store Road

Virginia Beach

VA

23455

(757) 213-3660

FIRE · SECURITY

www.VSCFire.com

Important: Deficiencies, comments and explanations of any FAIL or NEGATIVE responses are indicated on the Work Acknowledgment attachment for this Inspection/Test.

Frequency: Annual	Inspection Type: Portable Fire Extinguisher Inspection
In Accordance with:	
Technician's Name: Christine Clay	Inspection Date: 4-20-21
LOCATION	
Location Name: SPIRIT OF NORFOLK 01033S0377 2001059	
Street Address: 109 EAST MAIN STREET SUITE 500	
City: NORFOLK	State: VA Zip Code: 23510-1657
BILLING	
Billing Name: SPIRIT OF NORFOLK	
Street Address: 109 EAST MAIN STREET SUITE 500	
City: NORFOLK	State: VA Zip Code: 23510-1657
CONTACT INFORMATION	
Name: [REDACTED]	Phone: [REDACTED]
Email: [REDACTED]	
NOTIFICATIONS	
<input checked="" type="checkbox"/> NOTE: If checked, this Inspection test does not require disabling/restoring a Fire System and/or notifying a Monitoring Service.	
Date(s) put on test:	Time(s) put on test:
Date(s) restored:	Time(s) restored:
Monitoring Company and Operator Name(s) notified of test and restoral:	
Name(s) of Owner, Owner's Rep., Occupants and/or Tenants notified of test, restoral and any deficiencies:	
Local Emergency Services, AHJ, or Insurance Rep. notified of test, restoral or any impairments, if required:	
TECHNICIAN'S COMMENTS	
Any known adverse conditions noted which existed prior to this inspection and test:	Issues regarding restoral, or conditions which preclude restoral of Fire Protection Equipment/System(s):
 	Updated inspection report

Portable Fire Extinguisher Inspection Report
 No part of a report of a marine casualty investigation shall be admissible as evidence in any civil or administrative proceeding, other than an administrative proceeding initiated by the United States. 46 U.S.C. §6308.

ID # / Area / Location	Manufacturer	Model	Extinguisher Type	Size	Serial Number	Manuf. Date	6 Yr Maint Last Date	Hydro Test Last Date	Inspection		
									Pass	Fail	N/I
#1 GALLEY (ENGINE ROOM)	Buckeye	10hi	ABC	10 lb	F58854826	1/1/19	01/01/2019	01/01/2019	✓		
#2 GALLEY (ENGINE ROOM)	Buckeye	C02	CO2	10 lb	C84289212	1/1/16		01/01/2021	✓		
#3 GALLEY Scullery	AMEREX CORP.	B456	ABC	10 lb	F97375913	1/1/20			✓		
#4 GALLEY Scullery	Buckeye	Co2	CO2	10 lb	C84289210	1/1/16		01/01/2021	✓		
#5 GALLEY Bottom of stairs	AMEREX CORP.	B456	ABC	10 lb	X-820878	1/1/10	01/01/2016		✓		
#6 GALLEY bottom of stairs	Buckeye	CO2	CO2	10 lb	B08175845	1/1/15		01/01/2021	✓		
#7 Aft bar	BADGER-POWH	10 MB 8H	ABC	10 lb	Z-292430	1/1/10	01/01/2016	01/01/2010	✓		
#8 main level aft buffet	Buckeye	CO2	CO2	5 lb	B0674195	1/1/16		01/01/2021	✓		
#10 main level front buffet	Amerex	B456	ABC	10 lb	A34440830	1/1/14	01/01/2020		✓		
#11 Main level front dining	Ansul	Cd 05A1	CO2	5 lb	Ac399010	1/1/15		01/01/2018	✓		
#12 Bow Thruster	AMEREX CORP.	B456	ABC	10 lb	A34437958	1/1/14	01/01/2020		✓		
#13 01 Aft exit	Badger	CO2	CO2	5 lb	Z313320	1/1/06		01/01/2021	✓		
#14 01 Deck Aft buffet	AMEREX CORP.	B456	ABC	10 lb	B70350980	1/1/16	01/01/2016	01/01/2016	✓		
#15 Fwd Dining	Badger	5mb6h	ABC	5 lb	U767327	1/1/10	01/01/2016	01/01/2010	✓		
#16 01 fwd buffet	Amerex	B402	ABC	5 lb	Ay161876	1/1/12	01/01/2018		✓		
#17 02 Aft deck	Amerex	B456	ABC	10 lb	B70350358	1/1/16	01/01/2016	01/01/2016	✓		
#18 02 in bar	BADGER-POWH	10mb6h	ABC	10 lb	Z292390	1/1/10	01/01/2016	01/01/2010	✓		
#19 02 Pilot house	Buckeye	CO2	CO2	5 lb	Ac604862	1/1/15		01/01/2021	✓		
#9 1st deck RESTROOM Hall	AMEREX CORP.	B456	ABC	10 lb	B70350975	1/1/16	01/01/2016	01/01/2016	✓		

